

JOB ADDRESS \_\_\_\_\_  
WIND SPEED \_\_\_\_\_  
EXPOSURE \_\_\_\_\_



**These Tables Are For  
One and Two Family Dwellings**

Doors , Windows and Soffits Installed In Buildings with a  
Mean Roof Height of 30' or Less Located Exposures B & C

Table R301.2 [2]

**COMPONENTS AND CLADDING WORST CASE DESIGN PRESSURE [PSF]**

- 130 EXPOSURE B ZONE 4 = + 30.4 - 33.0 (One and Two)  
130 EXPOSURE B ZONE 5 = + 30.4 - 40.7 (Story)
- 130 EXPOSURE C ZONE 4 = + 36.8 - 39.9 (One Story)  
130 EXPOSURE C ZONE 5 = + 36.8 - 49.3
- 130 EXPOSURE C ZONE 4 = + 42.6 - 46.2 (Two Story)  
130 EXPOSURE C ZONE 5 = + 42.6 - 57.0
- 140 EXPOSURE B ZONE 4 = + 35.3 - 38.2 (One and Two)  
140 EXPOSURE B ZONE 5 = + 35.3 - 47.2 (Story)
- 140 EXPOSURE C ZONE 4 = + 42.7 - 46.2 (One Story)  
140 EXPOSURE C ZONE 5 = + 42.7 - 57.1
- 140 EXPOSURE C ZONE 4 = + 49.4 - 53.5 (Two Story)  
140 EXPOSURE C ZONE 5 = + 49.4 - 66.1

\*End-Zone 5 is NEVER less than 4 ft

**WINDOWS**

REMOVE EXISTING WINDOWS, SECURE EXISTING BUCKS PRIOR TO  
INSTALLING NEW WINDOWS. HAVE PRODUCT APPROVAL AVAILABLE AT  
TIME OF INSPECTION. **Glazing in hazardous locations must comply with R308.4**

**DOORS**

REMOVE EXISTING EXTERIOR DOOR, SECURE EXISTING BUCKS PRIOR TO  
REPLACING DOOR. HAVE PRODUCT APPROVALS AVAILABLE .AT TIME OF  
INSPECTION

**SHUTTERS**

INSTALL SHUTTERS PER R301.2.1.2 F.B.C AND HAVE PRODUCT APPROVALS  
AVAILABLE AT TIME OF INSPECTION.

**NOTES:**

- Per Florida Existing Building Code 606.4(1) Shutter or impact-resistant glass is required when more than 25% of the glazed openings are replaced within any 12-month period.
- Means of Escape must be provided / maintained per Florida Building Code R310.4